



Vadodara Gas Limited
Replies to Bidder's Queries

SUBJECT: Electrical Works (Supply, Laying, Installation, Testing, Termination and Commissioning, etc.) at Racecourse CNG Mother Station

TENDER NO.: VGL/CO/C&P-CNG/BD202508S244 Dated 18/09/2025 & **TENDER ID:** **225585.**

Sl. No.	Sec. No.	Page No.	Clause No.	Subject	Bidder's Query	VGL's Reply
1	SCC – IV	72	2	Delivery Period	Delivery Period minimum 6-8 Week due to TC, VCB& Panel all are make to Order Item not ready in three Week	Tender Conditions Prevail
2	SCC- IV	72	5	Warranty Period	5 Year Is Too High for Warranty please make it 1 year if possible for Panel & VCB (For TC is OK 5 Year)	Tender Conditions Prevail
3	-	-	-	Panel Room Size	Please mention Panel Room Size, Door Size	Panel Room Size: - 3.2 Mt X 2.50 Mt Door Size: - 1.96 Mt X
4	-	-	-	-	Kindly Clarity whether civil work, such as digging earth / breaking RCC flooring to install cable, removing paver block from existing flooring and paving anew after cable is laid, is part of the bidder scope and cost to be considered.	Yes, Digging Earth / breaking, removing paver block from existing flooring, and paving a new after cable is laid, Excavation, RCC Braking, Restoration of RCC, Plinth Structure work, fencing transformer all works in scope of Bidder.
					Further also inform if bidder scope includes fencing transformer area and putting surface material such as gravel.	Yes, scope of Bidder.

Note: This Replies to Bidder's Queries as uploaded on n-Procure & VGL's Website. Please upload the same duly Sign and Seal with Techno-Commercial Bid as this is an Integral Part of the Tender.