



VADODARA GAS LIMITED

REPLIES TO BIDDER'S QUERIES DATED 05/09/2022

TENDER NO.: VGL/CO/C&P-CNG/BD202208044 DATED 22/08/2022 & TENDER ID: 544351

TENDER SUBJECT: PURCHASE OF 3000 WL CAPACITY CASCADES ON ARC BASIS FOR PERIOD OF ONE YEAR

With reference to the above subject tender, replies to bidder's queries have been addressed below:

S. N.	SECTION NO. & NAME & PAGE NO.	CLAUSE NO. & DESCRIPTION	BIDDER'S QUERY	VGL'S REPLY
1	Section IV – SSC Page No. 62	8.0. Payment Terms	100% Payment within 30 days of receipt and acceptance of material along with the despatch documents.	Tender Conditions Prevail.
2	Section IV – SSC Page No. 63	13.0. Guarantee/ Warranty	Warranty shall be 12 months from commissioning of the material or 18 months from the date of despatch whichever is earlier for any manufacturing defects. Any defects reported shall be rectified.	Tender Conditions Prevail.
3	-	-	Paint coat thickness 300 micron has the tendency to peel off. Hence, EKC propose to offer final paint thickness of ~140 microns with each coat thickness of 40-60 microns. Surface preparation- Sand Blasting instead of shot Blasting. Shot blasting is not allowed for open frame as it is hazardous for the workers and the environment.	Three coats of paint shall be applied with minimum thickness of 300 micron. Surface preparation- Sand Blasting.
4	Section – II	Bidder's Eligibility Criteria [BEC]	We will submit photocopy of the chartered Engineer certified copy of WO and completion certificate and duly Notarised. VGL may refer to the original copy submitted in tender No. VGL/CO/ C&P-CNG/ BD202108161	Tender Conditions Prevail.

ALL OTHER TERMS AND CONDITIONS SHALL REMAINS UNCHANGED

NOTE: A COPY OF THESE REPLIES TO BIDDER'S QUERIES AS ISSUED ON n-procure & VGL WEBSITE ALONG WITH SIGN AND SEAL OF THE BIDDER WILL BE REQUIRED TO BE SUBMITTED WITH TECHNO-COMMERCIAL BID AS THIS WILL BE AN INTEGRAL PART OF THE TENDER.