



Vadodara Gas Limited
Replies to Bidder's Queries-Additional-II

SUBJECT: Procurement of Metering Regulating Skid (MRS) on ARC Basis for Period of 02 Years.

TENDER NO.: VGL/CO/C&P-PNG/BD202607P350 Dated 31/08/2026 & **TENDER ID:** 340605.

Sl. No.	Sec. No.	Page No.	Clause No.	Subject	Bidder's Query	VGL's Reply																								
1	Section – II	Page – 17-18	3.0	Methodology for Evaluation, Comparison & Award	The bidder has understood that the total supply will distribute between three bidders. Please clarify	As the total work is to be distributed into 03 nos. of bidders The ranking of bidders (L1, L2, L3) shall be determined by the bidder's evaluated price (arrived after applying quoted %age increase / decrease on total estimated price and GST) in ascending order. Complete work shall be awarded to 03 bidders as per below mentioned Table <table><tr><th>Rank</th><th>%age of Total Scope</th></tr><tr><td>L1</td><td>50</td></tr><tr><td>L2(*)</td><td>25</td></tr><tr><td>L3(*)</td><td>25</td></tr></table> (*): Upon matching with price as quoted by L1 bidder. All acceptable bidders other than L1 (irrespective of their ranks) shall be asked to confirm matching their price with L1 bidder in a single step to save on time and order shall be placed (in additional to L1 bidder) on the other 02 bidders who have agreed to match the L1 price and are lowest in order of their rankings. In case the total work cannot be distributed due to “Non – availability of requisite numbers of acceptable bidders to match the L1 price “ or “availability of less than requisite numbers of acceptable bidders agreeing to match L1 price”, attempt shall be made to re-distribute the balance quantity proportionately among the acceptable bidders (Including L1 bidder) who have agreed to match L1price as specified above to each bidder or work shall be distributed in %age as provided in below table. <table><tr><th>Rank</th><th>%age of Total Scope</th><th>%age of Total Scope</th><th>%age of Total Scope</th></tr><tr><td>L1</td><td>50</td><td>60</td><td>100</td></tr><tr><td>L2(*)</td><td>25</td><td>40</td><td>-</td></tr><tr><td>L3(*)</td><td>25</td><td>-</td><td>-</td></tr></table> In case of a tie at the lowest bid (L1) position between two or more bidders, the order/ LOA will be placed on the bidder having higher/ highest turnover in last audited financial year. In case of a tie at any position between two or more bidders, the preference for matching L1 rate will be asked to the bidder who having higher/ highest turnover in last audited financial year.	Rank	%age of Total Scope	L1	50	L2(*)	25	L3(*)	25	Rank	%age of Total Scope	%age of Total Scope	%age of Total Scope	L1	50	60	100	L2(*)	25	40	-	L3(*)	25	-	-
Rank	%age of Total Scope																													
L1	50																													
L2(*)	25																													
L3(*)	25																													
Rank	%age of Total Scope	%age of Total Scope	%age of Total Scope																											
L1	50	60	100																											
L2(*)	25	40	-																											
L3(*)	25	-	-																											
2	-	-	-	-	Battery Life of EVC 15 years battery life is not at all possible and no OEM can give this confirmation. You can check with all the OEM as mentioned in your vendor list itself and as per our knowledge of supplying EVC for last more than 20 years, no OEM	EVC battery life shall be offered for up to 10 years in case of a non-replaceable battery and up to 5 years in case of a replaceable battery. In case of a replaceable battery, a spare battery shall be provided to ensure a minimum overall battery life of 10 years.																								



Vadodara Gas Limited
Replies to Bidder's Queries-Additional-II

					can meet this requirement. Battery can last maximum 5 years for all the major make of EVC suppliers.	
3	-	-	-	-	All gas companies in India including VGL promoter i.e Gail Gas accepts either of PESO or ATEX for these devices and in absence of PESO ask for an undertaking. Please allow ATEX/PESO as it being allowed by all the gas companies in India.	Noted. ATEX/IECEX/CSA approvals shall be submitted, and an undertaking for PESO approval may be submitted along with the technical bid.
4	-	-	-	-	Please note this clause is not there in any tender and is only being put in VGL tenders and multiple bidder has raised same query. Further, 4 out of 5 RPD meter makes mentioned by you as approved vendor do not meet this requirement and neither any standard requires this. RPD meter needs to comply to the EN standard and all the requirement for the meter to work satisfactorily are taken care off once it passes EN approval. Some manufacturer can design the meters differently and can have different components, putting that as a requirement in tender over and above to complying standard which no gas company in India asks will result in no competition as only 1 vendor has it.	Confirmed. The meter shall be as per EN 12480. No plastic components shall be used in the pressure-containing body of the meter. If plastic components are used elsewhere inside the meter, the bidder shall ensure a minimum meter life of 15 years and submit the following documents: 1. W&M repair licence from an NABL-accredited laboratory, along with a supporting letter confirming that the laboratory will provide repair support for the meter OEM to the bidder. 2. Service and spare support letter from the meter OEM confirming availability of service and spare parts support for a minimum period of 15 years.
5	-	-	-	-	Since VGL has allowed PTR based vendor approval, we understand that the above clause as mentioned in the Notes section is not applicable.	Noted and accepted. The bidder is requested to submit the PTR along with a performance certificate/work completion certificate from a PSU for the requested make, size, and model, along with the technical bid.

Note: This Replies to Bidder's Queries as uploaded on n-Procure & VGL's Website. Please upload the same duly Sign and Seal with Techno–Commercial Bid as this is an Integral Part of the Tender.